

[Home](#)

[Home Page](#)

[Login](#)

[Logout](#)

[Remote Request](#)

Work Order List

WorkOrderID	Location	Received Date	Comp. Date	Status	Priority	Description	Resolution
Details '30653685'	FCPS, WEST POTOMAC HS	2/2/2016	2/2/2016	C	R	West Potomac HS. Water leak coming from a pipe in the ceiling inside exit 13, near the gym, james teasley took last night	Leak in ceiling by gym entrance at Exit 6. Cut away some insulation, determined leak to be HVAC. Contacted security, they called out HVAC technician on call, created new work order for him.
Details '30652649'	FCPS, WEST POTOMAC HS	1/29/2016	2/4/2016	C	R	Trade :Electrical-Edison: Repair non-working light fixture in room 101. Give to Steve :Truck 2557:	Check it. Replacement of lamp ballast. Rewiring of lampholders.
Details '30652280'	FCPS, WEST POTOMAC HS	1/28/2016	2/2/2016	C	R	replace toilet in room 330 broken	2575 1/28/16 mg. replacing toilet on 1/29/16. Broken behind spud has hair line crack. Replaced toilet on 1/29/16.
Details '30652237'	FCPS, WEST POTOMAC HS	1/28/2016	2/3/2016	C	R	Please repair broken vinyl floor tile next to room 440 Quander.	Repaired floor tile next to room #440 ,Quander building .. Complete 02/03/16. ART
Details '30651325'	FCPS, WEST POTOMAC HS, SPRINGBANK BLD2, 1ST FLOOR, CORRIDOR COR1-1	1/21/2016	1/29/2016	C	R	Please repair water fountain next to room 333 handle sticking keeps running.	2575 JT 1-21-2016. Repaired water cool change out valve assembly.
Details '30650658'	FCPS, WEST POTOMAC HS, 2ND FLOOR, 1ST FLOOR, CORRIDOR COR1-10	1/20/2016	1/28/2016	C	R	Repair water coolers send to truck 2762 CHECK BUILDING FOR HEAT, POWER AND DAMAGES DURING SNOW STORM	check units these have plumbing problems I will check with plumbing dept. 58915&58914
Details '30650545'	FCPS, WEST POTOMAC HS	1/20/2016	2/3/2016	C	R		building will not allow remoting in
Details '30649335'	FCPS, WEST POTOMAC HS	1/14/2016	1/20/2016	C	R	Please replace paper towel dispenser in Boys restroom 128A gunston building.	Replaced 1 paper towel dispenser
Details '30649247'	FCPS, WEST POTOMAC HS	1/14/2016	1/20/2016	C	R	Please Replace paper Towel dispenser in boys restroom 116 Gunston building.	Replaced 2 paper towel dispenser
Details '30649245'	FCPS, WEST POTOMAC HS	1/14/2016	1/20/2016	C	R	Please replace soap dispenser in restroom 212 gunston building.	Replaced 4 soap dispenser
Details '30648869'	FCPS, WEST POTOMAC HS	1/13/2016	1/29/2016	C	R	Trade :Electrical-Edison: Repair non-working light fixture in work room 327. Give to Steve :Truck 2557:	Check it. Replace lamp ballast. Rewiring of lampholders.
Details '30648610'	FCPS, WEST POTOMAC HS	1/13/2016	2/3/2016	C	R	missing stair riser tread on stairs going upstairs next to room 325	Repaired riser in stairs next to room # 325 ... Complete 02/01/16. ART..
Details '30648608'	FCPS, WEST POTOMAC HS	1/13/2016	2/1/2016	C	R	Missing rubber floor tile at side door to entrance 3	Repaired floor tile next to exit # 3 .. Complete 01/20/16 ART
Details '30648545'	FCPS, WEST POTOMAC HS	1/13/2016	1/15/2016	C	E	Please repair generator fault in Spring Bank Building. Thanks - Assigned To: #2725 please replace hand paper towel dispenser in boys restrooms next to room custodian	Assigned to Vehicle#: 2725 and Employee #: 108a paged on 1/13/2016 7:03:15 AM.repaired generator,test and run.install block heater and new antifreeze
Details '30648533'	FCPS, WEST POTOMAC HS	1/13/2016	1/20/2016	C	R	closet #450 than you	Replaced 1 paper towel dispenser
Details '30648532'	FCPS, WEST POTOMAC HS	1/13/2016	1/20/2016	C	R	please replace hand paper dispenser in room #459 lady restroom. thank you	Replaced 1 paper towel dispenser

[Forms](#)

[Work Order Request](#)

[Work Order Search](#)

[Custodial Request](#)

[Custodial Request Search](#)

[Return to Requestline](#)

[Return to Requestline](#)

[This software is powered by](#)



You are logged in as west
potomac

Welcome to TeamWORKS
Work Orders System.

TeamWORKS Web
Applications 2010 Version 2
Build 200

Session login countdown

[Details '30648434'](#)

FCPS, WEST POTOMAC HS, GUNSTON HALL
BLD3, 1ST FLOOR, BOILER ROOM 1059

1/12/2016 1/14/2016 C E

BOILER IS IN ALARM

Found false flame signal on Boiler 2.
Checked scanner, checked connections.
Reset and cycled. After heating up boiler it
still reads false flame. Left power to boiler
off. Scanner needs replaced. Ron Finelli has
a separate work order.

[Details '30647987'](#)

FCPS, WEST POTOMAC HS, 2ND FLOOR, 1ST
FLOOR, CLASSROOM 1044A

1/12/2016 2/3/2016 C

PM SHOP AIR COMPRESSOR (TA)
please re-place hand paper towel dispenser
in teacher work room #459 quander

Pm unit

[Details '30647804'](#)

FCPS, WEST POTOMAC HS

1/12/2016 1/20/2016 C R

Rubber stair tread needs regluing on steps
next to room 319 Quander.

Replaced 1 paper towel dispenser
Repaired stair tread next to room #319..
Complete 01/20/16... ART

[Details '30647709'](#)

FCPS, WEST POTOMAC HS

1/11/2016 2/1/2016 C R

Door #6 on Trailer 1397 at West Potomac
has a weak locking mechanism on it.

Hinges ripped out of doors on two
trailers,engineer made wo for carpenters
shop, temp fixed no wood left for screws

[Details '30647352'](#)

FCPS, WEST POTOMAC HS

1/11/2016 1/13/2016 C R

Please replace the parking lot lamps spots
148 and 147 in front of Quander building.
It's very dark in that area and not safe for
the studentds/faculty. Thank you!

Replaced six 400 watt my bulbs and located
time clocks and contactors

[Details '30647083'](#)

FCPS, WEST POTOMAC HS

1/8/2016 1/15/2016 C S

Need sand for to fill trash can for side walk
att. appiah

complete
2575 1/6/16 mg. snaked drain on sink in
room 196. draining fine now. looked like
grease in the line.
2575 1-6-2015JT. snaked drain in auto lab
draining fine now.

[Details '30646274'](#)

FCPS, WEST POTOMAC HS

1/6/2016 1/12/2016 C R

drain in sink in room 196 needs to be
snaked out clog up.(plumbing shop)

[Details '30646144'](#)

FCPS, WEST POTOMAC HS

1/6/2016 1/13/2016 C R

Please unclog drain line in mopsink room 5
auto shop.(plumbing dept.)

[Details '30646017'](#)

FCPS, WEST POTOMAC HS

1/6/2016 1/12/2016 C R

12345678910...
Item 1 to 25 of 316

Page:
of 13 Page size:

